



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901  
Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 1/23/24

Sample collection date: 1/29/24

Samples analyzed for E. Coli.

#### ANALYSIS RESULTS

<u>Location</u>	<u>Collection time</u>	<u>Results</u>
Site #2	1257	E. Coli – 10.8 cfu per 100mls
Site #3	1308	E. Coli – 42.2 cfu per 100mls
Site #4	1315	E. Coli – 76.8 cfu per 100mls

On 1/26/24 and 1/29/24 sample results were below 630 cfu's per 100mls at each designated site. No further testing is required.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs