



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: This is an ongoing overflow that began on 1/8/24

Location of event: Gulpha (Manhole 1750)

Sample collection date and time: 2/15/24 @ 1308

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 1: E. Coli – 18.7 cfu per 100mls  
(Overflow Location)

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. This is an ongoing overflow. This is the fifth test for this event. We will check the site weekly through the ending of this overflow.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs