



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 10/28/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 10/31/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1320	E. Coli – 101.4 cfu per 100mls
Site 3A:	1331	E. Coli – >2419.6 cfu per 100mls
Site 3B:	1340	E. Coli – 1046.3 cfu per 100mls
Site 4:	1304	E. Coli – 488.4 cfu per 100mls
Site 5:	1346	E. Coli – 313.0 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs