



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 10/28/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 11/3/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1239	E. Coli – 35.0 cfu per 100mls
Site 3A:	1249	E. Coli – 172.5 cfu per 100mls
Site 3B:	1257	E. Coli – 16.1 cfu per 100mls
Site 4:	1226	E. Coli – 26.6 cfu per 100mls
Site 5:	1308	E. Coli – 12.1 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs