



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 10/28/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 11/6/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0829	E. Coli – 78.4 cfu per 100mls
Site 3A:	0843	E. Coli – 104.6 cfu per 100mls
Site 3B:	0850	E. Coli – 16.8 cfu per 100mls
Site 4:	0815	E. Coli – 7.4 cfu per 100mls
Site 5:	0901	E. Coli – 7.2 cfu per 100mls

On 11/3/23 and 11/6/23 sample results were below 630 cfu's per 100mls at each designated site. No further testing is required.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs