



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 10/30/23

Sample collection date: 11/2/23

Samples analyzed for E. Coli.

ANALYSIS RESULTS

| <u>Location</u> | <u>Collection time</u> | <u>Results</u> |
|-----------------|------------------------|-------------------------------|
| Site #2 | 1117 | E. Coli – 30.1 cfu per 100mls |
| Site #3 | 1122 | E. Coli – 19.7 cfu per 100mls |
| Site #4 | 1127 | E. Coli – 18.5 cfu per 100mls |

On 11/1/23 and 11/2/23 sample results were below 630 cfu's per 100mls at each designated site. No further testing is required.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs