



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 11/9/23

Date and time of notification: 11/10/23 @ 0910

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date and time: 11/10/23 @ 1004

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 613.1 cfu per 100mls
(Overflow Location)

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. No further testing is required.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs