



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 12/25/23

Date and time of notification: 12/25/23 @ 0735

Location of event: Gulpha (Manhole 1750)

Sample collection date and time: 12/25/23 @ 0917

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 1299.7 cfu per 100mls
(Overflow Location)

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, site 4 and site 5 until two consecutive samples are below 630 cfu's per 100mls.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs