



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 12/25/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 1/2/24

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	1301	E. Coli – 4.1 cfu per 100mls
Site 3A:	1313	E. Coli – 17.3 cfu per 100mls
Site 3B:	1322	E. Coli – 15.8 cfu per 100mls
Site 4:	1247	E. Coli – 8.5 cfu per 100mls
Site 5:	1334	E. Coli – 6.3 cfu per 100mls

On 12/31/23 and 1/2/23 test results were below the 630 cfu's per 100 mls at site #2, site #3, site #4, and site #5. No further testing is required.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs