



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 12/9/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 12/18/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 3B:	1321	E. Coli – 23.1 cfu per 100mls
Site 4:	1305	E. Coli – 12.0 cfu per 100mls
Site 5:	1335	E. Coli – 34.1 cfu per 100mls

On 12/12/23 and 12/14/23 results at site #2 were below 630 cfu per 100 mls. On 12/14/23 and 12/15/23 results at site #3A were below 630 cfu per 100 mls. Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at site #3B, site #4, and site #5.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs