



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 4/9/24

Date and time of notification: 4/9/24 @ 1008

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date and time: 4/9/24 @ 1036

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 1: E. Coli – >2419.6 cfu per 100mls  
(Overflow Location)

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, site 4 and site 5 until two consecutive samples are below 630 cfu's per 100mls.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs