



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 6/29/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 7/12/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 3: E. Coli – 980.4 cfu per 100mls

Site 4: E. Coli – 8.5 cfu per 100mls

Site 5: E. Coli – 10.9 cfu per 100mls

On 7/2/23 and 7/3/23 results were below 126 cfu's at site #2. Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #3, site #4, and site #5

Tina Mietzner  
Laboratory Technician

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs