



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflows: 6/29/23, 7/7/23 and 7/8/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 7/13/23

Samples analyzed for: E.coli

ANALYSIS RESULTS

Site 2: E.coli – 34.1 cfu per 100mls

Site 3: E.coli – 227.9 cfu per 100mls

Site 4: E.coli – 6.3 cfu per 100mls

Site 5: E.coli – 78.0 cfu per 100mls

Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #2, site #3, site #4, and site #5

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs