



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901  
Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflows: 6/29/23, 7/7/23, 7/8/23 and 7/13/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 7/21/23

Samples analyzed for: E.coli

#### ANALYSIS RESULTS

Site 3: E.coli – 116.0 cfu per 100mls

Site 4: E.coli – 143.0 cfu per 100mls

Site 5: E.coli – 71.7 cfu per 100mls

On 7/14/23 and 7/16/23 results at site #2 were below 126 cfu per 100mls. On 7/20/23 and 7/21/23 results at site #3 were below 126 cfu per 100mls. Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #4 and site #5.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs