



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901
Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflows: 6/29/23, 7/7/23, 7/8/23 and 7/13/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 7/25/23

Samples analyzed for: E.coli

ANALYSIS RESULTS

Site 4: E.coli – 6.3 cfu per 100mls

Site 5: E.coli – 2.0 cfu per 100mls

On 7/14/23 and 7/16/23 results at site #2 were below 126 cfu per 100mls. On 7/20/23 and 7/21/23 results at site #3 were below 126 cfu per 100mls. On 7/24/23 and 7/25/23 results were below the 126 cfu's per 100 mls at site #4 and site #5. No further testing is required at this time.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs