



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 8/8/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 8/15/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 2: E. Coli – 13.1 cfu per 100mls

Site 3A: E. Coli – 55.2 cfu per 100mls

Site 3B: E. Coli – 4.1 cfu per 100mls

Site 4: E. Coli – 3.1 cfu per 100mls

Site 5: E. Coli – 5.2 cfu per 100mls

Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #2, site #3, site #4, and site #5.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs