



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901  
Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 8/8/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 8/16/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 2: E. Coli – 17.7 cfu per 100mls

Site 3A: E. Coli – 24.1 cfu per 100mls

Site 3B: E. Coli – 1.0 cfu per 100mls

Site 4: E. Coli – 95.9 cfu per 100mls

Site 5: E. Coli – 24.9 cfu per 100mls

On 8/15/23 and 8/16/23 sample results were below 126 cfu's per 100 mls at each designated site. No further testing is required.

Steven Rynders  
Laboratory Technician

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs