



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901
Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 8/8/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 8/9/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 2: E. Coli – 461.1 cfu per 100mls

Site 3: E. Coli – >2419.6 cfu per 100mls

Site 4: E. Coli – 13.2 cfu per 100mls

Site 5: E. Coli – 31.5 cfu per 100mls

Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #2, site #3, site #4, and site #5.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs