



# CITY OF HOT SPRINGS

---

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 9/23/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 9/23/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 1: E. Coli – 18.1 cfu per 100mls  
(Overflow Location)

This test result is below the EPA recommended 126 cfu's per 100mls at designated Site #1. No further testing is required.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs