



# CITY OF HOT SPRINGS

---

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

## SSO ANALYSIS REPORT

Date of overflow event: 01/02/23-01/03/23

Location of event: Hot Springs Creek

Sample collection date & time: 01/03/23 @1030

Samples analyzed for: E. Coli

### ANALYSIS RESULTS

108 Tatum E. Coli - >2419.6 cfu per 100mls  
(Overflow Location)

Testing will continue until two consecutive results are below 630 cfu per 100 mls at designated Sites.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs