



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Manhole 1750

Date of overflow event: 1/2/23-1/6/23

Sample collection date: 1/6/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 1: E. Coli – 67.7 cfu per 100mls  
(Overflow Location)

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. This meets the requirements of the newly revised procedure for SSO's. No further testing is required.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs