



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 01/02/23-01/03/23

Location of event: 1539 Spring St. (Manhole 4118)

Sample collection date & time: 01/03/23 @ 1307

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Manhole 4118 E. Coli – >2419.6 cfu per 100mls
(Overflow Location)

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs