



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 4/29/23

Sample collection date: 5/4/23

Samples analyzed for E. Coli.

#### ANALYSIS RESULTS

Site #2 E. Coli – 6.3 cfu per 100mls

Site #3 E. Coli – 248.1 cfu per 100mls

Site #4 E. Coli – 9.7 cfu per 100mls

On 5/3/23 & 5/4/23 results were below 126 cfu at Site #2. Testing will continue until two consecutive samples are below 126 cfu's per 100mls Site #3 and Site #4.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs