



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 3/24/23

Sample collection date: 3/27/23

Samples analyzed for E. Coli.

ANALYSIS RESULTS

Site #2 E. Coli – 344.8 cfu per 100mls

Site #3 E. Coli – 214.2 cfu per 100mls

Site #4 E. Coli – 46.5 cfu per 100mls

Testing will continue until two consecutive samples are below 630 cfu's per 100mls at each designated site.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs