



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 01/02/23-01/03/23

Location of event: 108 Tatum Street (Hot Springs Creek)

Sample collection date & time: 01/05/23 @ 1237-1254

Samples analyzed for E. Coli.

ANALYSIS RESULTS

Site 2: E. Coli – 648.8 cfu per 100mls
(110 Four Oaks Lane)

Site 3: E. Coli – 488.4 cfu per 100mls
(532 Grand Point Drive)

Site 4: E. Coli – 517.2 cfu per 100mls
(700 Grand Point Drive)

Testing will continue until two consecutive results are below the recommended 630 cfu per 100mls at designated Site #2, Site #3, and Site #4.

Tina Mietzner
Lab Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs