



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 4/29/23

Sample collection date: 4/29/23

Samples analyzed for E. Coli.

ANALYSIS RESULTS

Site #1 E. Coli - >2419.6 cfu per 100mls

Testing will continue until two consecutive samples are below 630 cfu's per 100mls at each designated site.

A handwritten signature in blue ink that reads "Amanda Cates". The signature is written in a cursive style.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs