



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 4/29/23

Sample collection date: 5/8/23

Samples analyzed for E. Coli.

ANALYSIS RESULTS

Site #3 E. Coli – 3.1 cfu per 100mls

Site #4 E. Coli – 15.8 cfu per 100mls

On 5/3/23 & 5/4/23 results were below 126 cfu at Site #2. Testing will continue until two consecutive samples are below 126 cfu's per 100mls Site #3 and Site #4.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs