



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 4/20/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 5/4/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 5: E. Coli – 30.5 cfu per 100mls

On 5/3/23 & 5/4/23 results were below the 126 cfu's per 100 mls at site #5.

On 4/25/23 & 4/27/23 results at Site #2, Site #3, and Site #4 were below 126 cfu's.

This completes testing for the overflow that started on 4/20/23.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs