



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 5/4/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 5/4/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 77.6 cfu per 100mls

This test result is below the EPA recommended 126 cfu's per 100mls at designated Site #1. This meets the requirements of the newly revised procedure for SSO's. No further testing is required for the overflow of 5/4/23.

Tina Mietzner
Laboratory Tech

Harold Mauldin
Facilities Operations Manager
City of Hot Springs