



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 3/3/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 3/7/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 2: E. Coli – 47.1 cfu per 100mls

Site 3: E. Coli – 64.4 cfu per 100mls

Site 4: E. Coli – 275.5 cfu per 100mls

Site 5: E. Coli – 70.3 cfu per 100mls

Results for samples taken on 3/6/23 & 3/7/23 were below the EPA recommended 630 cfu's per 100mls. This meets procedure requirements. No further testing is currently required.

  
Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs