



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Manhole 1750

Date of overflow event: 6/29/23

Sample collection date: 6/30/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 866.4 cfu per 100mls
(Overflow Location)

This test result is above the EPA recommended 126 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, site 4 and site 5 until two consecutive samples are below 126 cfu's per 100mls.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs