



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 1/28/23-present

Location of event: Manhole 1750

Sample collection date: 2/1/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – >2419.6cfu per 100mls
(Overflow Location)

Testing will continue until two consecutive results are below 630cfu per 100mls at designated Sites.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs