



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 1/28/23-2/5/23

Location of event: Manhole 1750

Sample collection date: 2/7/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 2: E. Coli – 25.6 cfu per 100mls

Site 3: E. Coli – 88.2 cfu per 100mls

Site 4: E. Coli – 16.8 cfu per 100mls

Site 5: E. Coli – 36.8 cfu per 100mls

These test results are the second consecutive results below the EPA recommended 630 cfu's per 100mls at designated site 2, site 3, site 4, and site 5. This meets the requirements of the newly revised procedure for SSO's. No further testing is required.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs