



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 2/8/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 2/13/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 2: E. Coli – 17.3 cfu per 100mls

Site 3: E. Coli – 14.6 cfu per 100mls

Site 4: E. Coli – 28.1 cfu per 100mls

Site 5: E. Coli – 9.5 cfu per 100mls

Testing will continue until two consecutive results are below the 630 cfu's per 100 mls at each designated site.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs