



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Gulpha (Manhole 1750)

Date of overflow event: 2/24/23

Sample collection date: 2/24/23

Samples analyzed for E. Coli.

ANALYSIS RESULTS

Site #1 E. Coli - >2419.6 cfu per 100mls

Testing will continue until two consecutive samples are below 630 cfu's per 100mls.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs