



# CITY OF HOT SPRINGS

---

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Gulpha (Manhole 1750)

Date of overflow event: 3/3/23

Sample collection date: 3/3/23

Samples analyzed for E. Coli.

#### ANALYSIS RESULTS

Site #1            E. Coli  $\rightarrow$  2419.6 cfu per 100mls

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, and site 4 until two consecutive samples are below 630 cfu's per 100mls.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs