



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Gulpha (Manhole 1750)

Date of overflow event: 3/16/23

Sample collection date: 3/17/23

Samples analyzed for E. Coli.

ANALYSIS RESULTS

Site #1 E. Coli ->2419.6 cfu per 100mls

This test result is above the EPA recommended 630 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, and site 4 until two consecutive samples are below 630 cfu's per 100mls.


Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs