



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 3/16/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 3/22/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 2: E. Coli – 61.3 cfu per 100mls

Site 3: E. Coli – 65.7 cfu per 100mls

Site 4: E. Coli – 23.5 cfu per 100mls

Site 5: E. Coli – 101.7 cfu per 100mls

Results for samples taken on 3/20/23 & 3/22/23 were below the EPA recommended 630 cfu's per 100mls. This meets procedure requirements. No further testing is currently required.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs