



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 4/20/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 5/3/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 5: E. Coli – 3.0 cfu per 100mls

Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #5.  
On 4/25/23 & 4/27/23 results at Site #2, Site #3, and Site #4 were below 630 cfu's.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs