



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 5/11/23

Sample collection date: 5/16/23

Samples analyzed for E. Coli.

ANALYSIS RESULTS

Site #2 E. Coli – 91.0 cfu per 100mls

Site #3 E. Coli – 21.3 cfu per 100mls

Site #4 E. Coli – 7.4 cfu per 100mls

On 5/15/2023 and 5/16/23 sample results were below 126 cfu's per 100mls at each designated site. No further testing is required.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs