



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 5/10/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 5/18/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 2: E. Coli – 57.1 cfu per 100mls

Site 3: E. Coli – 101.4 cfu per 100mls

Site 4: E. Coli – 15.8 cfu per 100mls

Site 5: E. Coli – 72.3 cfu per 100mls

On 5/16/23 and 5/18/23 results for Site 2 were below 126 cfu. Testing will continue at Site 3, Site 4, and Site 5 until two consecutive results are below the 126 cfu's per 100 mls at each site.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs