



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Manhole 1750

Date of overflow event: 5/29/23

Sample collection date: 5/29/23

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 53.8 cfu per 100mls
(Overflow Location)

This test result is below the EPA recommended 126 cfu's per 100mls at designated Site #1. This meets the requirements of the procedure for SSO's. No further testing is required.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs