



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Manhole 1750

Date of overflow event: 7/7/23

Sample collection date: 7/7/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 1: E. Coli – 648.8 cfu per 100mls  
(Overflow Location)

This test result is above the EPA recommended 126 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, site 4 and site 5 until two consecutive samples are below 126 cfu's per 100mls.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs