



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Manhole 1750

Date of overflow event: 7/8/23

Sample collection date: 7/12/23

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 2: E. Coli – 101.4 cfu per 100mls

Site 3: E. Coli – 980.4 cfu per 100mls

Site 4: E. Coli – 8.5 cfu per 100mls

Site 5: E. Coli – 10.9 cfu per 100mls

Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #2, site #3, site #4, and site #5

Tina Mietzner  
Laboratory Technician

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs