



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive, Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflows: 6/29/23, 7/7/23, 7/8/23 and 7/13/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 7/17/23

Samples analyzed for: E.coli

#### ANALYSIS RESULTS

Site 3: E.coli – >2419.6 cfu per 100mls

Site 4: E.coli – 16.0 cfu per 100mls

Site 5: E.coli – 18.1 cfu per 100mls

On 7/14/23 and 7/16/23 results at site #2 were below 126 cfu per 100mls. Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #3, site #4, and site #5

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs