



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflows: 6/29/23, 7/7/23, 7/8/23 and 7/13/23

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 7/18/23

Samples analyzed for: E.coli

ANALYSIS RESULTS

Site 3: E.coli – 456.9 cfu per 100mls

Site 4: E.coli – 4.1 cfu per 100mls

Site 5: E.coli – 25.4 cfu per 100mls

On 7/14/23 and 7/16/23 results at site #2 were below 126 cfu per 100mls. Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #3, site #4, and site #5

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs