



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Hot Springs Creek (Manhole 1865 & 1866 )

Date of overflow event: 2/8/23

Sample collection date: 2/15/23

Samples analyzed for E. Coli.

#### ANALYSIS RESULTS

Site #2 E. Coli – 770.1 cfu per 100mls

Site #3 E. Coli – 1732.9 cfu per 100mls

Site #4 E. Coli – 328.2 cfu per 100mls

Testing will continue until two consecutive samples are below 630 cfu's per 100mls.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs