



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 12/30/22-1/1/23

Location of event: Manhole 1750

Sample collection date & time: 1/1/23 @ 1032

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 30.5 cfu per 100mls
(Overflow Location)

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. This meets the requirements of the newly revised procedure for SSO's. No further testing is required.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs