



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 11/27/22-11/28/22

Location of event: Manhole 1750

Sample collection date & time: 11/28/22 @ 1013

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 1: E. Coli – 125.9 cfu's per 100mls  
(Overflow Location)

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. This meets the requirements of the newly revised procedure for SSO's. No further testing is required.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs