



# CITY OF HOT SPRINGS

---

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Sample collection date: 12/14/22

Samples analyzed for E. Coli.

#### ANALYSIS RESULTS

108 Tatum St.          E. Coli – 547.5 cfu per 100mls

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. This meets the requirements of the newly revised procedure for SSO's. No further testing is required.

Amanda Cates  
Laboratory Manager

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs